



Typical Analysis

Extrabond Off White Tile Adhesive

VOC Content Test Certificate

Manufacturer: Westbuild Products Pty Ltd

Product: Extrabond Off White Tile Adhesive

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Extrabond Off White
Ceramic Tile Adhesive 65 grams per Litre	10 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Extrabond Offwhite
Ceramic Tile Adhesive 65 grams per Litre	10 grams per Litre as VOC content per coating

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ ACA, AIRAH, FMA
Managing Director and Principal Consultant

Date of Test: April 2009.
Tested by CETEC Pty Ltd. 2/27 2/27 Normanby Rd, Notting Hill, VIC 3168
Australia. - T: +613 9544 9111